INVITATION TO BID ADDENDUM

STATE OF LOUISIANA

DIVISION OF ADMINISTRATION
OFFICE OF STATE PURCHASING

====> VENDOR NO. :

 SOLICITATION:
 2239404

 FILE NO.:
 Q12002N

 OPENING DATE:
 05/18/10

VENDOR NAME AND ADDRESS

<-FOLD

FILL IN VENDOR NUMBER (FEIN), NAME AND ADDRESS ABOVE, BEFORE SUBMITTING BID.

BIDS WILL BE PUBLICLY OPENED:

MAY 18, 2010 10:00 AM

PURCHASING AGENCY NO.: 107001

RETURN BID TO

2239404 05/18/10 10:00 AM Q12002N

OFFICE OF STATE PURCHASING OFFICE OF STATE PURCHASING POST OFFICE BOX 94095 BATON ROUGE, LA 70804-9095

BUYER : JANA BRAUD
BUYER PHONE : (225) 342-8036
DATE ISSUED : 04/22/10
REQ. AGENCY : 326246

DHH-OFFICE OF PUBLIC HEALTH

AGENCY REQ. NO.

ISIS REQ. NO. : 1331524

VENDOR PHONE

FISCAL YEAR : 10
CLASS/SUBCLASS : 07022
SCHEDULED BEGIN DATE : 05/18/10
SCHEDULED END DATE : 06/30/10

T-NUMBER

GENERATOR TANDEM AXLE TRAILERS

QUESTIONS AND STATE'S RESPONSE ADDENDUM NUMBER 01 APRIL 29, 2010

YOUR REFERENCE IS DIRECTED TO FILE NUMBER Q12002N, SOLICITATION NUMBER 2239404 FOR GENERATOR, TANDEM AXLE TRAILERS FOR DEPARTMENT OF HEALTH AND HOSPITALS IS SCHEDULED TO OPEN AT 10:00AM ON 5/18/10.

QUESTIONS AND THE STATE'S RESPONSES:

1. HOW MANY TRAILERS ARE REQUIRED?

RESPONSE: A QUANTITY OF FOUR, AS INDICATED ON PAGE 11, LINE 1, IN QUANTITY COLUMN

2. ARE THERE DRAWINGS OF THE TRAILERS?

FOLD->

RESPONSE: NO DRAWINGS WERE PROVIDED WITH SOLICITATION, THE BRAND AND MODEL NUMBERS ARE REFERENCED ON PAGE 11 UNDER LINE 00001.

3. WHAT TYPE OF FLOORING WOULD BE PREFERRED, WOOD OR METAL?

RESPONSE: NO FLOORING IS INDICATED IN SPECIFICATIONS.
REFERENCE MQ POWER MODEL #TRLR45US2 OR EQUAL.

4. IS THERE A SPECIFIC MOUNTING POINT THAT THE GENERATOR WILL SIT ON OR WILL YOUR OFFICE MAKE MOUNTING HARDWARE TO SECURE THE GENERATOR TO THE TRAILER?

RESPONSE: SEE PAGE 9, #19 SPECIFICATION "STRUCTURAL CHANNEL FOR MOUNTING AND SUPPORT", REFERENCE MQ POWER MODEL TRLR45US2

VENDOR PHONE NUMBER: FAX NUMBER:	TITLE	DATE

SIGNATURE OF BIDDER (MUST BE SIGNED)

OLICITATION AMENDMENT TEXT	INVITATION TO BID	
UMBER: 2239404 PEN DATE: 05/18/10 TIME: 10:00 AM -NUMBER:	BIDDER:	PAGE 2
5. IS THE 142.4 AN OAL LENGTH OR LENGTH OF JUST THE FLAT DECK AREA?		
5. IS THE 142.4 AN OAL LENGTH OR	LENGTH OF JUST THE FLAT DECK AREA?	
5. IS THE 142.4 AN OAL LENGTH OR RESPONSE: OVERALL LENGTH OF TRAI REFERENCE MQ POWER MOD	LER.	

ADDENDUM DOES NOT CAUSE YOU TO REVISE YOUR BID, YOU SHOULD ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY IDENTIFYING YOUR BUSINESS NAME AND BY SIGNING WHERE INDICATED. YOU MAY RETURN THIS ACKNOWLEDGEMENT BY MAIL TO: OFFICE OF STATE PURCHASING, PO BOX 94095, BATON ROUGE, LA 70804-9095, BY HAND DELIVERY TO: OFFICE OF STATE PURCHASING, 1201 NORTH 3RD ST, CLAIBORNE BLDG STE 2-160, BATON ROUGE, LA, 70802 OR BY FAX TO: (225)342-8688. THE STATE RESERVES THE RIGHT TO REQUEST A COMPLETED ACKNOWLEDGEMENT AT ANY TIME. FAILURE TO EXECUTE AN ACKNOWLEDGEMENT SHALL NOT RELIEVE THE BIDDER FROM COMPLYING WITH THE TERMS OF ITS BID.

ADDENDUM ACKNOWLEDGED / NO CHANGES:

FOR: ______ BY: ______

REVISION: IF YOU HAVE ALREADY SUBMITTED YOUR BID AND THIS ADDENDUM REQUIRES YOU TO REVISE YOUR BID, YOU MUST INDICATE ANY CHANGE(S) BELOW IDENTIFY YOUR BUSINESS NAME AND SIGN WHERE SHOWN. REVISIONS SHALL BE DELIVERED PRIOR TO BID OPENING BY MAIL TO: OFFICE OF STATE PURCHASING, PO BOX 94095, BATON ROUGE, LA 70804-9095, BY HAND DELIVERY TO: OFFICE OF STATE PURCHASING, 1201 NORTH 3RD ST, CLAIBORNE BLDG STE 2-160, BATON ROUGE, LA, 70802 AND INDICATE THE FILE NUMBER, BID OPENING DATE, AND TIME ON THE OUTSIDE OF THE ENVELOPE FOR PROPER IDENTIFICATION, OR BY FAX TO (225) 342-8688. ELECTRONIC TRANSMISSION OTHER THAN BY FAX IS NOT BEING ACCEPTED AT THIS TIME.

REVISIONS RECEIVED AFTER BID OPENING SHALL NOT BE CONSIDERED AND YOU SHALL BE HELD TO YOUR ORIGINAL BID.

REVISION:	
FOR:	BY: